

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmision Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2007-08

Sl. No.	Total Injection to Delhi System	Apr-07	May-07	Jun-07	Jul-07	Aug-07	Sep-07	Oct-07	Nov-07	Dec-07	Jan-08	Feb-08	Mar-08	Total 07-08
1	IP	75.259442	81.268047	76.300135	72.994125	79.954378	66.515987	65.910458	79.072878	77.851467	70.927699	69.153359	72.712726	887.920698
2	GT	105.958744	93.131504	93.189061	99.938010	122.950699	105.406410	111.695848	105.306626	119.716473	79.675401	84.988238	132.019976	1253.976991
3	RPH	55.105966	75.336597	37.306830	73.723944	71.647306	72.279935	76.863994	71.401904	63.762303	71.698361	46.259951	65.538974	780.926065
4	Pragati GT	211.939169	207.380285	189.028441	204.976843	208.779196	195.251583	209.184024	176.688240	206.364936	189.769828	220.143956	80.055076	2299.561577
5	BTPS	352.911522	440.227595	409.290401	374.008776	296.722392	393.667368	441.224652	462.920508	487.444949	483.298437	413.493034	392.707124	4947.916758
6=(1 to 5)	Total drawal from the generating sources within Delhi	801.174843	897.344027	805.114867	825.641698	780.053971	833.121283	904.878976	895.390157	955.140128	895.369726	834.038538	743.033876	10170.302089
7	Drawal from the grid	1127.845121	1269.069136	1442.059484	1511.457878	1501.422247	1273.941079	783.089675	578.862977	629.059066	788.013153	695.349152	810.421451	12410.590419
8=(6+7)	Total input to Delhi system	1929.019964	2166.413163	2247.174351	2337.099576	2281.476218	2107.062362	1687.968651	1474.253134	1584.199194	1683.382879	1529.387690	1553.455327	22580.892508
Drawal by DISCOMs														
9	NDPL	522.476318	582.965117	609.792074	642.920871	625.985153	589.122458	484.789584	424.433829	459.067033	467.308998	427.878664	437.990528	6274.730627
10	BRPL	804.601579	905.891437	942.143748	968.759259	933.063675	856.183167	673.222509	598.405349	642.519410	694.065646	623.040663	629.595650	9271.492091
11	BYPL	451.972264	513.719717	530.757824	547.620324	544.912638	501.527707	399.583676	337.609163	357.471085	383.249618	353.306674	363.021989	5284.752678
12	NDMC	105.584350	123.014329	125.966039	131.554170	129.319493	117.818369	89.788943	75.534286	81.387752	91.023301	81.281708	82.125295	1234.398036
13	MES	15.013912	16.713941	16.849274	18.177835	18.081001	16.646632	13.378091	12.755523	16.867050	20.120631	16.156199	13.760742	194.520831
14=(9 to 13)	Total drawal by DISCOMs	1899.648423	2142.304541	2225.508959	2309.032459	2251.361960	2081.298332	1660.762803	1448.738151	1557.312330	1655.768193	1501.663908	1526.494204	22259.894263
15=(8-14)	Transmission losses in MUs	29.371540	24.108622	21.665393	28.067117	30.114258	25.764030	27.205848	25.514983	26.886864	27.614685	27.723782	26.961123	320.998245
16=15*100/8	Transmission losses in %	1.52	1.11	0.96	1.20	1.32	1.22	1.61	1.73	1.70	1.64	1.81	1.74	1.42

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmission Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2008-09

Sl. No.	Total Injection to Delhi System	Apr-08	May-08	Jun-08	Jul-08	Aug-08	Sep-08	Oct-08	Nov-08	Dec-08	Jan-09	Feb-09	Mar-09	Total 08-09
1	IP	76.857969	88.3193987	67.000353	66.049576	55.821018	44.903700	51.814047	52.473589	73.478484	75.28223	78.691795	86.446657	817.138817
2	GT	61.9395843	48.049069	60.547257	70.380735	64.55845904	63.96986	64.624706	66.4282867	67.6354339	63.2163365	60.799607	64.066825	756.216159
3	RPH	131.9539228	101.72003	85.640017	91.869347	105.387998	94.674619	115.835871	99.93697074	99.495656	99.0364346	92.8428842	119.151429	1237.545179
4	Pragati GT	124.227536	217.993296	213.13842	215.057288	190.077424	206.380768	214.065084	214.831486	223.523382	166.695414	156.057768	192.474396	2334.522262
5	BTPS	434.402318	434.964553	441.54181	458.190576	411.166584	375.716976	406.059216	362.272272	443.01684	465.600936	421.61748	453.011928	5107.561489
6=(1 to 5)	Total drawal from the generating sources within Delhi	829.381330	891.046347	867.867857	901.547522	827.011483	785.645923	852.398924	795.942604	907.149796	869.831351	810.009534	915.151235	10252.983906
7	Drawal from the grid	963.736839	1199.443741	1311.048689	1483.856343	1419.824668	1309.414114	1056.389121	674.813104	632.100235	762.216284	593.572804	653.65454	12060.070482
8=(6+7)	Total input to Delhi system	1793.118169	2090.490088	2178.916546	2385.403865	2246.836151	2095.060037	1908.788045	1470.755708	1539.250031	1632.047635	1403.582338	1568.805775	22313.054388
	Drawal by DISCOMs													
9	NDPL	496.2841654	575.1879943	611.4176853	664.2606578	622.930849	584.4405891	535.5314972	426.2930017	453.9380817	472.0046463	419.1264648	463.8845352	6325.300168
10	BRPL	729.6889949	852.0656416	878.7522249	969.4613529	911.3072454	837.0321946	762.3681606	584.7761165	613.9110782	652.743032	552.3533351	620.4378448	8964.897221
11	BYPL	425.10131	496.5482678	521.1615919	565.2997379	536.2491747	508.3952945	461.4779586	348.7736597	352.9526861	374.6648904	324.7393092	367.225239	5282.589120
12	NDMC	98.90814552	115.675126	119.170809	132.1348291	122.532608	116.9963164	106.1124266	75.08931414	77.349316	84.3709196	68.9084292	79.516603	1196.764843
13	MES	14.1767514	15.442082	16.2791094	18.375856	17.5268921	16.181724	14.79065116	12.98691805	15.869637	19.284762	14.041854	13.473051	188.429288
14=(9 to 13)	Total drawal by DISCOMs	1764.159367	2054.919112	2146.781421	2349.532434	2210.546769	2063.046119	1880.280694	1447.919010	1514.020799	1603.068250	1379.169392	1544.537273	21957.980640
15=(8-14)	Transmission losses in MUs	28.958802	35.570976	32.135125	35.871431	36.289382	32.013918	28.507351	22.836698	25.229232	28.979385	24.412946	24.268502	355.073749
16=15*100/8	Transmission losses in %	1.61	1.70	1.47	1.50	1.62	1.53	1.49	1.55	1.64	1.78	1.74	1.55	1.59

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmission Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2009-10

Sl. No.	Total Injection to Delhi System	Apr-09	May-09	Jun-09	Jul-09	Aug-09	Sep-09	Oct-09	Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Total 09-10
1	IP	80.132443	63.450719	53.299551	70.931071	43.909479	35.601540	30.353594	-1.956357	-0.254393	-0.761625	-1.006809	-0.579175	373.120039
2	GT	63.726171	54.958665	56.753739	46.893372	50.074362	33.627134	32.045932	29.964219	59.598432	22.070949	25.639866	75.248288	550.601129
3	RPH	119.462863	123.959335	125.479132	129.760589	144.048920	111.895444	140.680970	112.211323	103.874792	113.198115	107.281948	112.907152	1444.760583
4	Pragati GT	206.367378	213.655764	198.915955	154.534542	147.782226	208.730973	191.057092	211.009524	224.768544	216.962916	184.007856	224.022390	2381.815160
5	BTPS	380.067528	472.209732	463.540428	465.027156	391.196112	390.787620	423.240936	352.123848	342.920184	412.576428	281.284188	326.378532	4701.352692
6=(1 to 5)	Total drawal from the generating sources within Delhi	849.756383	928.234215	897.988805	867.146730	777.011099	780.642711	817.378524	703.352557	730.907559	764.046783	597.207049	737.977187	9451.649603
7	Drawal from the grid	1042.070823	1426.267058	1555.732655	1774.102512	1748.565001	1425.977764	1067.665746	817.703669	877.766587	1038.872269	855.730431	1042.204978	14672.659493
8=(6+7)	Total input to Delhi system	1891.827206	2354.501273	2453.721460	2641.249242	2525.576100	2206.620475	1885.044270	1521.056226	1608.674146	1802.919052	1452.937480	1780.182165	24124.309096
	Drawal by DISCOMs													
9	NDPL	542.744777	644.625693	685.488624	731.629304	706.830476	627.808340	557.569712	471.580058	483.250689	521.975062	452.052219	537.480955	6963.035908
10	BRPL	755.087723	971.052055	996.305749	1076.458228	1025.983852	881.393302	734.964750	583.965129	635.641594	727.185186	570.736102	707.881093	9666.654763
11	BYPL	453.769359	562.699178	585.111189	632.488371	604.817917	530.358793	455.087000	356.506832	371.456658	415.892884	329.437902	408.893472	5706.519555
12	NDMC	99.720573	124.208455	129.588901	140.756116	131.587828	115.248806	98.934409	74.666206	79.579371	93.940093	70.887383	88.430210	1247.548349
13	MES	14.940605	18.041798	18.567014	20.215603	19.390566	16.868466	14.985546	13.919512	17.587000	22.844806	15.222064	15.039622	207.622601
14=(9 to 13)	Total drawal by DISCOMs	1866.263036	2320.627180	2415.061476	2601.547622	2488.610638	2171.677707	1861.541416	1500.637737	1587.515312	1781.838031	1438.335669	1757.725352	23791.381177
15=(8-14)	Transmission losses in MUs	25.564170	33.874093	38.659984	39.701620	36.965463	34.942768	23.502854	20.418489	21.158834	21.081021	14.601811	22.456813	332.927919
16=15*100/8	Transmission losses in %	1.35	1.44	1.58	1.50	1.46	1.58	1.25	1.34	1.32	1.17	1.00	1.26	1.38

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmission Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2010-11

Sl. No.	Total Injection to Delhi System	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	Nov-10	Dec-10	Jan-11	Feb-11	Mar-11	Total 10-11
1	GT	120.418439	122.364108	127.144315	99.154438	80.089520	76.945645	134.020693	61.393068	160.682012	127.203768	101.440558	111.293364	1322.149928
2	RPH	55.388288	42.683690	41.713234	67.776259	71.157428	20.639673	26.050279	74.701076	67.756939	81.466798	58.562058	76.466558	684.362280
3	Pragati GT	204.867876	208.976490	203.067522	208.204164	205.010460	190.031226	171.527478	180.975473	217.134564	219.661404	199.605372	58.770618	2267.832647
4	BTPS	416.986188	339.519612	365.814580	316.593468	294.238862	279.573144	368.144592	270.400180	360.267336	386.020176	373.485840	404.016396	4175.060374
5	Bawana CCGT							6.755672	2.290800	-0.002618	0.015927	4.457018	3.428182	16.944980
6=(1 to 5)	Total drawal from the generating sources within Delhi	797.660791	713.543900	737.739651	691.728329	650.496270	567.189688	706.498714	589.760596	805.838233	814.368073	737.550845	653.975118	8466.350209
7	Drawal from the grid	1523.733300	1961.593942	1886.980257	2025.545658	1883.259290	1626.548353	1319.100694	996.324328	927.718843	1087.834749	798.344314	1077.757632	17114.741360
8=(6+7)	Total input to Delhi system	2321.394091	2675.137842	2624.719908	2717.273987	2533.755560	2193.738041	2025.599408	1586.084924	1733.557076	1902.202822	1535.895159	1731.732750	25581.091569
Drawal by DISCOMs and IP for auxiliary consumption as the station has been completely shutdown from 01.01.2010														
9	NDPL	650.839110	743.853915	728.581150	758.120627	715.047330	627.484555	571.484471	452.677719	496.459148	530.480475	450.074349	493.340479	7218.443326
10	BRPL	949.073978	1107.305876	1092.173235	1129.616441	1039.109124	892.625654	824.723123	649.547018	706.846554	772.217643	607.041380	690.719961	10460.999985
11	BYPL	548.496200	631.361962	617.194657	639.721573	603.474606	519.887445	484.423605	370.325587	397.279046	437.666860	353.992844	408.395979	6012.220362
12	NDMC	121.587124	135.958938	134.460212	135.043978	127.006425	111.507640	102.790983	77.830984	87.154941	112.290186	88.254054	104.269451	1338.154917
13	MES	18.243406	20.026782	19.676053	20.985605	19.540626	17.148549	15.341678	13.451856	19.403556	23.317898	14.763998	14.231309	216.131316
14	IP	1.308017	1.839455	2.010547	0.512356	0.410377	0.471218	0.278208	0.276261	0.302589	0.296203	0.318994	0.348092	8.372318
15=(9 to 14)	Total drawal by DISCOMs	2289.547835	2640.346928	2594.095853	2684.000579	2504.588487	2169.125062	1999.042068	1564.109424	1707.445834	1876.269265	1514.445618	1711.305271	25254.322223
16=(8-15)	Transmission losses in MUs	31.846256	34.790914	30.624055	33.273408	29.167072	24.612979	26.557340	21.975501	26.111242	25.933558	21.449541	20.427478	326.769346
17=16*100/8	Transmission losses in %	1.37	1.30	1.17	1.22	1.15	1.12	1.31	1.39	1.51	1.36	1.40	1.18	1.28

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER

(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmission Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2011-12

	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	557.455821	718.357989	732.661242	766.905778	740.324756	701.488467	580.550965	480.640982	519.685211	528.610037	486.112301	497.815592	7310.609142
BRPL	829.020669	1129.354578	1148.879593	1181.804387	1140.521908	1051.680666	845.326902	677.060165	732.243761	792.117459	678.527678	695.658635	10902.196401
BYPL	484.147675	639.797654	650.079113	669.944836	652.152883	603.599442	504.689041	387.246524	402.645492	429.752138	382.840600	396.335935	6203.231334
NDMC	102.744909	139.788524	146.585594	151.178018	144.038967	140.339219	113.146638	90.357938	94.178377	104.358287	93.179201	90.288435	1410.184107
MES	15.381952	19.875739	20.337667	21.384792	20.613626	19.480812	15.360900	13.651918	19.250828	24.256397	18.118621	14.630623	222.343876
IP	0.311598	0.325566	0.308840	0.323833	0.322674	0.313515	0.322686	0.312493	0.323342	0.323426	0.302304	0.332839	3.823115
Consumption	1989.062623	2647.500050	2698.852050	2791.541645	2697.974814	2516.902121	2059.397132	1649.270021	1768.327012	1879.417745	1659.080704	1695.062058	26052.387975
GT	89.633776	113.776967	104.722450	97.237835	102.316825	83.052183	115.204962	120.200415	136.713622	114.082719	54.062336	62.156495	1193.160585
RPH	77.504456	78.912856	72.626295	19.984923	60.616578	49.598166	67.020562	51.935333	52.374844	47.313382	63.216996	61.653774	702.758165
PPCL	157.629654	202.592280	181.472136	213.839700	215.823960	212.175810	223.950042	215.318634	223.276368	223.732812	204.428748	217.887204	2492.127348
BTPS	394.525524	411.996228	356.314632	371.161380	387.593124	346.037532	284.322636	292.820808	333.179820	410.825172	371.594700	401.382840	4361.754396
NRPC	1291.804200	1875.104182	2015.444904	2122.305947	1962.535810	1855.637658	1361.681676	927.814181	1009.695194	1055.915186	902.530567	917.506251	17297.975756
Bawana	4.591527	-0.225927	-0.240655	-0.169200	1.629164	-0.742145	34.065815	62.290249	35.058543	52.427123	83.126720	51.388468	323.199682
Actual drawal	2015.689137	2682.156586	2730.339762	2824.360585	2730.515461	2545.759204	2086.245693	1670.379620	1790.298391	1904.296394	1678.960067	1711.975032	26370.975931
Lossess in Mus	26.626514	34.656536	31.487712	32.818940	32.540647	28.857082	26.848561	21.109600	21.971379	24.878649	19.879364	16.912974	318.587957
Lossess in %	1.32	1.29	1.15	1.16	1.19	1.13	1.29	1.26	1.23	1.31	1.18	0.99	1.21

DELHI TRANSCO LIMITED
STATE LOAD DESPATCH CENTER

(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Computation of Transmission Losses of STU Delhi i.e. Delhi Transco Limited system for FY 2012-13

all figures are in Mus

	Apr	May	June	July	Aug'12	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	582.209506	740.432433	833.597415	833.166529	750.113639	714.211082	599.605526	479.402570	521.004422	562.280475	479.982986	533.898027	7629.904609
BRPL	866.578923	1159.552676	1311.166221	1283.589265	1112.922735	1056.041840	841.624607	668.921319	719.680068	813.515435	642.980769	671.579554	11148.153411
BYPL	494.312684	644.942908	726.512249	718.286149	642.389844	608.767487	500.856811	381.884899	405.100339	444.111363	360.950590	404.702878	6332.818200
NDMC	104.547242	136.533074	148.910330	148.137051	131.789616	124.999993	98.205434	73.712791	82.083756	98.563876	87.647045	129.948235	1365.078443
MES	16.298467	20.532662	22.533277	23.246041	20.815811	19.794911	15.934101	14.420934	19.455972	25.191672	17.330269	15.072246	230.626363
IP	0.308810	0.319417	0.208043	0.061755	0.057728	0.055672	0.056102	0.049332	0.048568	0.054208	0.047546	0.045861	1.313042
Consumption	2064.255631	2702.313170	3042.927535	3006.486789	2658.089374	2523.870985	2056.282581	1618.391844	1747.373125	1943.717029	1588.939204	1755.246801	26707.894068
GT	113.907758	153.822518	136.548387	138.774005	112.126965	73.355926	86.145943	92.178093	86.875893	98.821592	76.902919	98.961541	1268.421540
RPH	65.329191	58.648923	66.057575	29.171413	32.919764	51.550565	69.041002	67.379841	66.978535	69.714897	62.857134	41.357974	681.006815
PPCL	202.410948	208.205652	194.983762	203.068152	144.624835	202.441434	213.525696	218.860362	230.359404	227.344344	197.026314	198.992422	2441.843325
BTPS	352.612512	372.219156	287.346000	385.269888	361.430868	333.190296	371.113776	339.019260	304.672440	398.738472	268.712436	406.819056	4181.144160
NRPC	1252.787040	1810.633996	2303.787102	2151.762793	1893.506024	1873.660378	1218.286994	746.985286	942.227237	1018.693254	861.519014	977.031955	17050.881073
Bawana	102.617664	133.111625	92.453834	134.208630	143.382680	15.765135	120.718364	176.366020	137.326043	151.222475	138.179393	50.975362	1396.327226
Actual drawal	2089.665113	2736.641870	3081.176660	3042.254882	2687.991136	2549.963734	2078.831776	1640.788862	1768.439552	1964.535034	1605.197210	1774.138310	27019.624139
Lossess in Mus	25.409482	34.328701	38.249125	35.768093	29.901762	26.092748	22.549195	22.397018	21.066427	20.818005	16.258006	18.891509	311.730070
Lossess in %	1.22	1.25	1.24	1.18	1.11	1.02	1.08	1.37	1.19	1.06	1.01	1.06	1.15

DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Details of Transmission Losses of STU(Delhi) for FY 13-14

all figures are in Mus

	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	627.883387	808.672408	809.427346	857.324887	788.767720	792.224792	672.495713	501.663853	547.138068	582.474467	510.815799	540.370481	8039.258921
BRPL	891.974850	1228.082976	1231.690423	1261.036983	1148.994708	1145.581710	914.493297	669.438786	725.146640	819.084863	672.648195	699.218252	11407.391682
BYPL	508.594316	690.563705	695.686633	726.325109	677.008671	674.338206	549.126375	390.723732	413.459771	455.671382	387.122970	408.384665	6577.005534
NDMC	109.287063	147.795812	151.689236	151.835087	138.761362	137.862276	113.526242	81.924690	89.280008	106.475230	86.396317	85.156433	1399.989756
MES	17.135170	22.083855	21.711079	23.277752	21.328371	21.210301	17.376643	14.720879	18.963685	25.097717	18.767442	15.614171	237.287065
IP	0.055085	0.068754	0.058312	0.050401	0.050373	0.046929	0.048557	0.046991	-0.001215	-0.018527	-0.003445	0.016136	0.418352
Consumption	2154.929870	2897.267509	2910.263029	3019.850219	2774.911205	2771.264214	2267.066827	1658.518930	1793.986956	1988.785132	1675.747278	1748.760138	27661.351308
GT	125.603065	105.176329	97.128390	83.776839	71.194842	87.286526	68.962006	57.013349	64.282519	107.808065	81.884528	56.675615	1006.792073
RPB	69.319511	50.499413	49.362418	26.562662	33.803892	37.299270	30.473720	3.981197	-0.417832	-0.434436	4.545867	17.137227	322.132909
PPCL	195.757297	208.007958	170.021496	205.606350	195.714828	193.669938	184.577040	206.166828	218.389266	197.878092	191.893266	191.425932	2359.108291
BTPS	373.336884	392.320740	361.490904	324.192960	305.161800	310.605000	308.048832	224.793660	275.330964	350.355132	298.463054	248.669523	3772.769453
NRPC	1400.558137	2003.067911	2173.600530	2354.817126	2081.676158	2013.992038	1672.537326	1179.083450	1252.103159	1357.556484	1106.142994	1254.158536	19849.293849
Bawana	16.787398	170.201848	90.666038	58.484275	108.060827	151.081068	18.498853	-1.734675	-0.576048	-1.843724	10.601078	-2.902679	617.324258
Actual drawal	2181.362292	2929.274199	2942.269776	3053.440212	2795.612347	2793.933840	2283.097777	1669.303809	1809.112028	2011.319613	1693.530787	1765.164154	27927.420833
Lossess in Mus	26.432421	32.006690	32.006747	33.589992	20.701142	22.669625	16.030950	10.784880	15.125072	22.534481	17.783508	16.404016	266.069525
Lossess in %	1.21	1.09	1.09	1.10	0.74	0.81	0.70	0.65	0.84	1.12	1.05	0.93	0.95

DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Details of Transmission Losses of STU(Delhi) for FY 14-15

all figures are in Mus

	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	625.479493	780.289767	892.890909	923.825748	905.975670	815.261490	682.319295	541.695144	576.317068	602.971111	517.733113	559.513547	8424.272355
BRPL	855.591069	1151.737855	1340.562218	1369.705854	1327.788317	1145.009081	947.846327	687.641186	771.458220	848.922720	660.585102	716.911149	11823.759097
BYPL	492.490231	656.941038	747.606103	778.291612	753.212216	658.668128	552.038289	399.268361	426.806998	462.087747	375.319311	414.380230	6717.110265
NDMC	102.165444	136.149920	158.031431	164.194889	157.399161	139.830934	113.899987	85.966218	97.857398	110.691826	82.839286	87.635596	1436.662091
MES	16.182701	20.564510	23.769128	25.044768	24.210791	20.964017	17.178885	14.778250	21.804067	27.132577	16.670030	15.662953	243.962677
IP	0.017929	0.066868	0.139165	0.112651	0.107140	0.089547	0.047517	0.037734	0.038104	0.086105	0.071248	0.070222	0.884230
Consumption	2091.926868	2745.749958	3162.998954	3261.175522	3168.693294	2779.823197	2313.330300	1729.386893	1894.281854	2051.892086	1653.218090	1794.173697	28646.650714
GT	74.384204	88.116826	94.729640	108.615833	69.345920	78.066060	67.771093	56.663868	57.921110	94.134261	57.580468	56.932025	904.261308
RPB	32.141183	55.376239	64.771999	51.690319	41.637805	44.663544	-0.637858	-0.415953	-0.515144	24.762003	22.747438	21.389788	357.611363
PPCL	108.523020	83.944086	135.800304	210.186132	203.589666	201.766434	204.028032	136.674660	141.604692	137.039190	110.826630	125.261754	1799.244600
BTPS	237.734154	329.189496	384.046903	362.677980	258.085812	209.853307	286.979500	226.679700	186.234168	218.626476	107.932620	125.318710	2933.358826
NRPC	1651.825749	2159.636846	2344.472705	2364.924192	2366.899230	2060.074323	1503.817186	1109.432685	1297.020492	1371.433870	1175.168120	1292.500880	20697.206278
Bawana	2.083967	44.946318	157.116324	185.753647	251.714554	203.043710	266.316225	215.598513	230.594717	221.481131	191.728706	186.193670	2156.571481
Actual drawal	2106.692277	2761.209811	3180.937875	3283.848103	3191.272987	2797.467378	2328.274178	1744.633473	1912.860035	2067.476931	1665.983982	1807.596827	28848.253855
Lossess in Mus	14.765409	15.459853	17.938921	22.672581	22.579692	17.644181	14.943878	15.246580	18.578181	15.584844	12.765892	13.423130	201.603141
Lossess in %	0.70	0.56	0.56	0.69	0.71	0.63	0.64	0.87	0.97	0.75	0.77	0.74	0.70

DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Details of Transmission Losses of STU(Delhi) for FY 15-16

all figures are in Mus

	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	669.134108	862.761195	860.166724	883.883627	874.835918	867.939654	741.312228	546.545043	581.387511	592.003054	545.764671	590.333872	8616.067604
BRPL	902.913007	1277.010944	1271.072782	1266.894399	1265.192443	1245.213658	1003.217927	705.880122	746.573143	780.966864	681.954246	745.727470	11892.617004
BYPL	519.834516	722.345684	728.524879	728.480396	716.844607	709.519533	587.815270	401.039320	409.799581	424.526400	385.218032	427.770317	6761.718535
NDMC	110.389707	158.072973	163.216196	162.280520	160.688482	154.733010	125.343852	95.152354	104.496689	105.562057	90.356006	101.950797	1532.242643
MES	16.964401	22.505274	22.960480	23.430819	22.904220	22.183035	17.177862	13.546017	19.285390	22.508234	16.686280	15.436342	235.588353
IP	0.070001	0.079836	0.054041	0.042818	0.022789	0.039330	0.040423	0.027865	0.029070	0.032397	0.003734	-0.000057	0.442247
Consumption	2219.305740	3042.775906	3045.995101	3065.012579	3040.488458	2999.628220	2474.907562	1762.190721	1861.571385	1925.599006	1719.982969	1881.218740	29038.676387
GT	63.306798	70.144565	42.845687	45.847226	29.123165	24.989578	30.208266	28.904360	25.549333	30.287390	26.632387	27.547179	445.385934
RPB	14.495214	24.340009	-0.726725	-0.695064	-0.697079	-0.719975	-0.572396	-0.499884	-0.557956	-0.458274	-0.363064	-0.447167	33.097639
PPCL	142.668402	193.607280	171.140006	145.338918	135.112950	166.565454	105.812958	110.799732	107.145600	114.630690	98.407872	6.568374	1497.798236
BTPS	144.738150	230.146534	231.315084	272.018832	226.718096	193.324916	133.357326	115.294348	117.280824	119.480964	112.174944	117.268032	2013.118050
NRPC	1664.138609	2337.243906	2453.610488	2511.332887	2677.533920	2484.100482	2079.726239	1357.033958	1448.406702	1508.142656	1325.962828	1623.884984	23471.117659
Bawana	204.209186	208.802897	174.193126	117.148742	-3.635071	158.445072	148.274403	165.169033	182.370751	173.760380	174.258514	125.455806	1828.452838
Actual drawal	2233.556359	3064.285191	3072.377666	3090.991541	3064.155982	3026.705527	2496.806796	1776.701547	1880.195254	1945.843806	1737.073481	1900.277208	29288.970356
Lossess in Mus	14.250619	21.509286	26.382564	25.978961	23.667524	27.077307	21.899234	14.510825	18.623869	20.244800	17.090512	19.058468	250.293969
Lossess in %	0.64	0.70	0.86	0.84	0.77	0.89	0.88	0.82	0.99	1.04	0.98	1.00	0.85

DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)

Details of Transmission Losses of STU(Delhi) for FY 16-17

all figures are in Mus

	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec	Jan	Feb	Mar	Total
NDPL	757.597576	933.445061	977.748205	944.110683	918.470457	899.555471	774.853143	523.773854	552.501389	599.746783	556.488519	624.677075	9062.968214
BRPL	1052.692768	1356.744663	1460.998811	1367.843410	1321.248982	1274.877870	1054.745055	702.351009	735.747320	795.262557	669.508201	772.137621	12564.158267
BYPL	602.302308	757.197993	819.560411	771.889917	745.872449	722.493898	610.773645	379.384451	386.851388	418.220630	368.282451	445.086947	7027.916488
NDMC	137.919030	166.465601	163.849205	155.181739	151.820778	139.359916	113.607066	83.468594	86.507053	96.377702	77.769363	92.034673	1464.360719
MES	18.883839	23.531669	24.951192	24.494102	22.777938	22.125329	17.836665	14.157492	18.212575	22.305045	15.565096	15.274104	240.115046
IP	0.002581	0.007799	0.009109	0.010596	0.006203	0.005887	0.005182	0.003613	0.003829	0.004061	0.003131	0.002334	0.064325
Consumption	2569.398102	3237.392786	3447.116933	3263.530446	3160.196807	3058.418371	2571.820756	1703.139013	1779.823554	1931.916778	1687.616761	1949.212753	30359.583060
GT	24.430875	61.519488	83.157563	70.556257	50.037925	53.217097	56.645277	56.960129	58.702439	48.441840	53.761982	54.898862	672.329734
RPB	-0.517613	-0.471304	-0.565458	-0.574310	-0.381014	-0.336417	-0.363608	-0.279580	-0.286159	-0.333152	-0.290850	-0.399842	-4.799308
PPCL	161.989200	185.941902	180.166752	175.517578	161.131734	140.377461	114.642599	169.325126	162.421745	110.104349	106.367484	91.065114	1759.051044
BTPS	209.893848	195.829488	220.589640	234.883944	237.620400	234.867948	176.232552	19.487880	-5.103972	-5.187525	-4.705828	-3.054855	1511.353520
NRPC	2125.421532	2671.745962	2852.281588	2669.400928	2551.840828	2466.673135	2051.571504	1353.217167	1401.731780	1604.119274	1375.127235	1614.687168	24737.818101
Bawana	70.962910	155.822125	146.259117	140.366103	187.717859	190.322849	192.888559	122.413166	188.620508	195.112838	172.518909	205.780972	1968.785916
MSW Bawana	0.000000	0.000000	0.000000	-0.385823	-0.345559	0.294235	1.644362	1.652197	-0.147237	1.638077	2.877821	7.945143	15.173216
Actual drawal	2592.180752	3270.387661	3481.889202	3289.764677	3187.622173	3085.416307	2593.261245	1722.776085	1805.939104	1953.895701	1705.656753	1970.922562	30659.712223
Lossess in Mus	22.782649	32.994875	34.772269	26.234231	27.425366	26.997936	21.440489	19.637072	26.115550	21.978923	18.039992	21.709809	300.129163
Lossess in %	0.88	1.01	1.00	0.80	0.86	0.88	0.83	1.14	1.45	1.12	1.06	1.10	0.98